



CERTIFICATE

CONTROL PANELS OF FIRE PUMPS ACCORDING TO AS2941 STANDARD



Made by:

SVE corp

Albert Einstein, 36-B

Parque Tecnológico Álava

01510 Vitoria-Gasteiz

ESPAÑA

n° Identification

20240460

Product code:

0601

This certificate is valid for the configurations listed on the reverse side and is subject to the results of the follow-up audits and strict compliance with the procedure applicable to the Cepreven quality seal



You can check veracity and limitations of this certificate on the website www.cepreven.com



Certificate number
202404600601

Valid until:03/06/2025

Configurations covered by this certificate:

Diesel Engine driven configurable-programmable Fire Pumps Control Panel.Mod SCF840-D-AS y SCF C900-D-AS

Functional testing and design according to AS2941-2013

CE Marking Tests:

EMC Tests according to EN 50130-4:2011; IEC 62599-2:2010; EN 61000-6-3:2007

Electrical Safety Tests according to EN 61010-1:2011

Environmental Testing:

IP Protection Grade according to: EN 60529:2018

Degree of Impact Protection according to: EN 60068-2-75:2014

Climate Tests (Cold Test, Humid Heat Cycle, Components Temperature)

Vibration according to: EN60068-2-6:2008

Other Essays:

Battery Chargers

Pressure Sensor and Recorder